

ISBE ID	Building ID	Building Description	Sample Date	Sample Time (12 HR Clock)	Collected By	Sample ID Number	Sample Location Description	Fixture Type	Date of Last Use	Time of Last Use (12 HR Clock)	Sample Type	Sample Volume (mL)	Laboratory Name	Analytical Method	Concentration (ug/L)	Reporting Limit (ug/L)	Notes
14-016-1180-04-2003	0001	Palos West Elem.	6/6/17	7:13 AM	GT	PWE-D-01	By W. Door, Main Gym	F - Water Cooler	6/5/2017	9:00 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	Right Water Fountain
14-016-1180-04-2003	0001	Palos West Elem.	6/6/17	7:15 AM	GT	PWE-D-02	By W. Door, Main Gym	F - Water Cooler	6/5/2017	9:00 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	Right Water Fountain
14-016-1180-04-2003	0001	Palos West Elem.	6/6/17	7:17 AM	GT	PWE-D-03	By W. Door, Main Gym	F - Water Cooler	6/5/2017	9:00 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	Left Water Fountain
14-016-1180-04-2003	0001	Palos West Elem.	6/6/17	7:19 AM	GT	PWE-D-04	By W. Door, Main Gym	F - Water Cooler	6/5/2017	9:00 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	Left Water Fountain
14-016-1180-04-2003	0001	Palos West Elem.	6/6/17	7:21 AM	GT	PWE-D-05	By E. Door, Main Gym	F - Water Cooler	6/5/2017	9:00 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	Right Water Fountain
14-016-1180-04-2003	0001	Palos West Elem.	6/6/17	7:23 AM	GT	PWE-D-06	By E. Door, Main Gym	F - Water Cooler	6/5/2017	9:00 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	Right Water Fountain
14-016-1180-04-2003	0001	Palos West Elem.	6/6/17	7:25 AM	GT	PWE-D-07	By E. Door, Main Gym	F - Water Cooler	6/5/2017	9:00 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	Left Water Fountain
14-016-1180-04-2003	0001	Palos West Elem.	6/6/17	7:27 AM	GT	PWE-D-08	By E. Door, Main Gym	F - Water Cooler	6/5/2017	9:00 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	Left Water Fountain
14-016-1180-04-2003	0001	Palos West Elem.	6/6/17	7:29 AM	GT	PWE-D-09	At Restrooms by Rm 26	F - Water Cooler	6/5/2017	9:00 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	Right Water Fountain
14-016-1180-04-2003	0001	Palos West Elem.	6/6/17	7:30 AM	GT	PWE-D-10	At Restrooms by Rm 26	F - Water Cooler	6/5/2017	9:00 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	Right Water Fountain
14-016-1180-04-2003	0001	Palos West Elem.	6/6/17	7:32 AM	GT	PWE-D-11	At Restrooms by Rm 26	F - Water Cooler	6/5/2017	9:00 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	Left Water Fountain
14-016-1180-04-2003	0001	Palos West Elem.	6/6/17	7:33 AM	GT	PWE-D-12	At Restrooms by Rm 26	F - Water Cooler	6/5/2017	9:00 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	Left Water Fountain
14-016-1180-04-2003	0001	Palos West Elem.	6/6/17	7:35 AM	GT	PWE-S-13	Teachers' Lounge	S - Sink	6/5/2017	9:00 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
14-016-1180-04-2003	0001	Palos West Elem.	6/6/17	7:37 AM	GT	PWE-S-14	Teachers' Lounge	S - Sink	6/5/2017	9:00 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
14-016-1180-04-2003	0001	Palos West Elem.	6/6/17	7:39 AM	GT	PWE-D-15	At Restrooms by Rm 45	F - Water Cooler	6/5/2017	9:00 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	Right Water Fountain
14-016-1180-04-2003	0001	Palos West Elem.	6/6/17	7:41 AM	GT	PWE-D-16	At Restrooms by Rm 45	F - Water Cooler	6/5/2017	9:00 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	Right Water Fountain
14-016-1180-04-2003	0001	Palos West Elem.	6/6/17	7:43 AM	GT	PWE-D-17	At Restrooms by Rm 45	F - Water Cooler	6/5/2017	9:00 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	Left Water Fountain
14-016-1180-04-2003	0001	Palos West Elem.	6/6/17	7:44 AM	GT	PWE-D-18	At Restrooms by Rm 45	F - Water Cooler	6/5/2017	9:00 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	Left Water Fountain
14-016-1180-04-2003	0001	Palos West Elem.	6/6/17	7:46 AM	GT	PWE-D-19	At Restrooms by Rm 6	F - Water Cooler	6/5/2017	9:00 PM	First Draw	250	ARRO Laboratory	EPA 200.5	6.41	2.00	Right Water Fountain
14-016-1180-04-2003	0001	Palos West Elem.	6/6/17	7:47 AM	GT	PWE-D-20	At Restrooms by Rm 6	F - Water Cooler	6/5/2017	9:00 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	Right Water Fountain
14-016-1180-04-2003	0001	Palos West Elem.	6/6/17	7:50 AM	GT	PWE-D-21	At Restrooms by Rm 6	F - Water Cooler	6/5/2017	9:00 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	Left Water Fountain
14-016-1180-04-2003	0001	Palos West Elem.	6/6/17	7:51 AM	GT	PWE-D-22	At Restrooms by Rm 6	F - Water Cooler	6/5/2017	9:00 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	Left Water Fountain
14-016-1180-04-2003	0001	Palos West Elem.	6/6/17	7:52 AM	GT	PWE-S-23	Kitchen by Room 4	KS - Kitchen Sink	6/5/2017	9:00 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
14-016-1180-04-2003	0001	Palos West Elem.	6/6/17	7:54 AM	GT	PWE-S-24	Kitchen by Room 4	KS - Kitchen Sink	6/5/2017	9:00 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
14-016-1180-04-2003	0001	Palos West Elem.	6/6/17	7:56 AM	GT	PWE-S-25	Multipurpose Rm. Kit.	KS - Kitchen Sink	6/5/2017	9:00 PM	First Draw	250	ARRO Laboratory	EPA 200.5	5.38	2.00	
14-016-1180-04-2003	0001	Palos West Elem.	6/6/17	7:58 AM	GT	PWE-S-26	Multipurpose Rm. Kit.	KS - Kitchen Sink	6/5/2017	9:00 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
14-016-1180-04-2003	0001	Palos West Elem.	6/6/17	8:01 AM	GT	PWE-S-27	Nurse's Office	S - Sink	6/5/2017	9:00 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
14-016-1180-04-2003	0001	Palos West Elem.	6/6/17	8:02 AM	GT	PWE-S-28	Nurse's Office	S - Sink	6/5/2017	9:00 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
14-016-1180-04-2003	0001	Palos West Elem.	6/6/17	8:04 AM	GT	PWE-D-29	Hall by Classroom 16	F - Water Cooler	6/5/2017	9:00 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
14-016-1180-04-2003	0001	Palos West Elem.	6/6/17	8:06 AM	GT	PWE-D-30	Hall by Classroom 16	F - Water Cooler	6/5/2017	9:00 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
14-016-1180-04-2003	0001	Palos West Elem.	6/6/17	8:09 AM	GT	PWE-D-31	Hall by Classroom 15	F - Water Cooler	6/5/2017	9:00 PM	First Draw	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	
14-016-1180-04-2003	0001	Palos West Elem.	6/6/17	8:10 AM	GT	PWE-D-32	Hall by Classroom 15	F - Water Cooler	6/5/2017	9:00 PM	Flush	250	ARRO Laboratory	EPA 200.5	<2.00	2.00	